

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 6911-1496:0174

Page 1 of 2

CATEGORY: Voice Communication Systems Control Units

LISTEE: FIRECOM INC, 39-27 59th Street, Woodside, NY, 11377
Contact: Howard Kogen (718) 899-6100 Fax (718) 899-1932
Email: HKOGEN@FIRECOMINC.COM

DESIGN: Models CAR-2700, Series -2701, -2702, -2703, -2704, -2705, -2706, -2707 Central Audio Racks, DAC-2700-XX Distributed Audio Cabinet (where XX=70, 71, 72, 73, 74, 75, 76. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

| Model | Part Number | Description |
|-----------------|-------------|----------------------------|
| CAR 2000 Series | 5051 | Enclosure |
| MP-3 | 70877 | Mounting Plate |
| Bussbar Support | 70881 | Bussbar Support |
| Bussbar | 70880 | Bussbar |
| Screw Clamp | 70883 | Wire Clamps |
| Terminals | 70882 | Terminals |
| CAM 2000 | 70851 | Processor Board |
| AMC-1 | 70852 | Audio Monitor Card |
| Amplifier | 70582 | Amplifier |
| COM-1 | 70337 | Communications Card |
| DIS-1 | 70438 | Display Card |
| TGC-1 | 70855 | Tone Generator Card |
| ASM-1 | 600321 | Audio Signal Monitor |
| MDX-2 | 70886 | Digital Voice Card |
| Power Strip | 70887 | For Enclosure |
| Relays | 70879 | Amplifier Relays |
| Amplifier Panel | | Filler Plate for Amplifier |
| PS-6A, -6B | | Power Supply |

RATING: 120 VAC, 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as voice communication system control unit for use with listee's separately listed compatible fire alarm control units.

DRAFT

Draft for Signature

Signature/Date: _____

4-9-10 ma



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **April 09, 2010**

Listing Expires **June 30, 2010**

Authorized By: **FRANCIS MATEO**, Program Coordinator
Fire Engineering Division